



THE CITY OF REDMOND
FIRE DEPARTMENT - PREVENTION DIVISION
**Redmond Fire Department Standards
Administrative Ruling / Interpretation**



Code Section: 9.00, Devices

Standard Edition: 2000

Title: Fee Clarification

Date: January 1, 2004

Statement of Need:

Fees for permits and the determination of which alarm permit is to be used, are both dependent upon a calculation of the number of devices involved. Some question exists as to what constitutes a device.

Ruling/Interpretation: The following definition of device is provided to assist in the determination of what constitutes a device for the purpose of calculating fees for fire alarm permits and the determination of which alarm permit is to be used.

One fire alarm system device shall be considered *any one* of the following:

1. a spot detector
2. a visual notification appliance
3. an audible notification appliance
4. a combination audible/visual appliance
5. each piece of a beam detector system
6. a remote annunciator
7. a tamper switch
8. a valve closure switch
9. a hi/low pressure indicator switch
10. a manual initiating appliance
11. a supervisory switch connected to the alarm system
12. a secondary control panel
13. a secondary address point
14. a line type detector, per continuous line
15. a magnetic hold open device
16. or similar individual piece of equipment or appliance.

Note: An FACP, remote power supply or a transmitter are devices which are counted and charged separately and, therefore, are not added into the device count.

Robert Lovett
Fire Marshal